




Tubes Arrangement,
4 x 14 passes
Stutzen preparation= 15 mm

DETAIL A



ITEM CODE	UNIT'S NAME	PAINTING
704EM-AX0000011C	BRC 11.1(E)	Wet Paint RAL 5000
704EM-AX0000012C	BRC 11.2(E)	Wet Paint RAL 9005
704EM-AX0000013C	BRC 11.3(E)	Wet Paint RAL 6033
704EM-AX0000014C	BRC 11.4(E)	Wet Paint RAL 7035
704EM-AX0000015C	BRC 11.5(E)	Powder Coating - Green

Pressure test	35 bar
Delivered unit	Without air pressure, use plastic cap/rubber cap
Type Shield	Version A (Normal size)
Painting	acc. to table
Refrigerant	R22
Packing type	Pallet (P)
General Tolerance	DIN ISO 2768-v, DIN EN ISO 13920-D

TECHNICAL DATA										
Coil Type	E/4/14/2.40/1250/AXS/2			Fin's material	Alu, t 0.15 mm					
Tubes	Cu, Ripple X, 3/8" x 0.28 mm			Stirnblech	Galv. steel, t 1.25 mm					
Tube Pitch	50 x 25 mm			Ventilatoreblech	Galv. steel, t 1.25 mm					
Finspacing	2.4 mm			Bodenblech	Galv. steel, t 2.0 mm					
Circuits	No of Lines	No of Passes	Header Inlet		Header outlet		Vol of tubes (liter)	exch. surface (m ²)	weight Empty (kg)	weight Operation (kg)
			φ (mm)	Tube In φ (mm)	φ (mm)	Tube out φ (mm)				
A	4	14	35x15	I.D. 28.3	22x10	I.D. 16.3	5.9	70.4	ca. 35.6	-

For Production Only

POS		CHANGES		DATE	NAME
DRAWN		DATE		NAME	
REVIEW		DATE		NAME	

basetec
products + solutions GmbH
Dornier straÙe 4, 82178 Puchheim

SCALE: _____

POS: _____ CUSTOMER: _____

QUANTITY: -

DESCRIPTION: Condenser; BRC 11 (E)
BAT E/4/14/2.40/1250/AXS/2

DRAWING NO: 7-3-060-04486.dft

REVISION: 0

Page: 1/1

/pripadi/4/27/2011 ORDER NO: _____